





Baltimore SSO

Site Investigation Report

FM Initials: DF

Project: 21 Herring Run Siphons

Site Name:	21_94S	Monitor Series:	4000 WR	Monitor S/N:		Manhole #:		Investigation Information:
Address / Location:	Moravia Park Dr. - West of Moravia Rd.	Map Page #:		Map Grid #:		Upstream Input: (L/S, P/S) DNI		
		Pipe Height:	41.26"	Pipe Width:	41.75"	Upstream Manhole:		
		IP Address:				Downstream Manhole: Siphon Chamber		
Access:	Walk (Wooded)	GPS Coords:	N DD.dddd		W DD.dddd		Depth of Flow: 13.0" +/- 0.5"	
							Description of Site Hydraulics:	
Date/Time of Investigation:		10/19/04 12:30 PM						



Manhole Information:
Manhole Depth: 8.4'
Manhole Material / Condition: BRICK / Fair
Active Drop Connections? Yes - Pump Discharge

System Character:
<input checked="" type="checkbox"/> Residential
<input type="checkbox"/> Commercial
<input type="checkbox"/> Industrial

Notes:
SSO #94 Irregular Shape Pipe

Legend:
Cast Iron Flap Valve
Sensor Location
N.T.S.- Not to scale

Flow monitor was deactivated as of February 28, 2005 pending completion of Consent Decree Project #13.