

30-4076-01: Tulsa Metropolitan Utility Authority (TMUA) TMUA ES 2025-06

Smoke Observation Summary

Cleanout, Defective

Address: 1231 N Allegheny Ave

Basin: **CC-TL1415C**

Segment (US : DS): **094-0527:094-0526**


Intensity: **Low**

Drainage Area (SF): **30**

Surface: **Unpaved**

Comments: *Smoke from base of CO*

QC Comments: Need area photo showing roofline



Cleanout, Defective

Address: 1238 N Braden Ave

Basin: **CC-TL1415C**

Segment (US : DS): **094-0527:094-0526**

Intensity: **Low**

Drainage Area (SF): **1,000**

Surface: **Unpaved**

Comments: *Unable to access, locked gate*

QC Comments: Re-attempt access and get close up if possible

